

Wilmington Township

wilmingtontp@comcast.net

669 Wilson Mill Road

New Castle, PA 16105

Phone: 724-946-2560 Fax: 724-946-3185

Driveway Permit Application For Wilmington Township Lawrence County

Name: _____

Address: _____

Phone Number: _____

Name of Subdivision where driveway will be located or street name:

Lot #: _____

New 911 Address: _____

Permit Fee : \$ 10.00

Paid by Check #: _____

Date Paid: _____

Applicant Signature

**Applicant will need to review Driveway Locations and Standards prior to submitting an application.*

Wilmington Township

wilmingtontp@comcast.net

669 Wilson Mill Road

New Castle, PA 16105

Phone: 724-946-2560 Fax: 724-946-3185

Driveway Locations and Standards

- A. Driveway shall be located no less than sixty (60) feet from any street intersection (measured from the intersection of the ultimate right-of-way lines). Sight distance requirements for all residential and non-residential driveways shall be in accordance with PENNDOT Chapter 441.
- B. All driveways shall be at least five (5) feet from any side or rear lot line.
- C. All driveways shall be a minimum of eight (8) feet in width.
- D. Driveways shall be constructed to conform to the finished shoulder of the road or street. All descending or ascending driveway grades shall begin at the street right-of-way. No stormwater shall be permitted to drain onto streets from driveways.
- E. Intersection with cartways shall be installed minimum radii of five (5) feet at both sides.
- F. *Provisions "A" through "E" shall control unless there is a more restrictive PENNDOT regulation for the driveway's connection to State roads.*

Installation of Drainage Pipe

Driveways shall be constructed in a manner which does not impede the flow of stormwater into roadside drainage facilities. Drainage culverts are required as follows:

1. Driveway culverts must include flared end sections.
2. End of pipes must extend a minimum of five (5) feet beyond edge of paving.
3. Minimum pipe length is twenty (20) feet.
4. Minimum pipe size shall be fifteen (15) inch smooth bore plastic or otherwise approved by the Township Engineer or by PENNDOT if the driveway connects to a state road.
5. Where an existing roadside drainage swale is too shallow to permit installation of a driveway pipe, a concrete trench box with grate may be required to be installed to the grate. Trench boxes must extend beyond the edge of the driveway paving by a minimum of five (5) feet.